

## 2015 International Fire Code Operational Permits

IFC Code Reference	Activity or Operation	Permit Required
<b>105.1.1</b>	<b>Permits required</b>	Permits required by this code shall be obtained from the fire code official. Permit fees, if any, shall be paid prior to issuance of the permit. Issued permits shall be kept on the premises designated therein at all times and shall be readily available for inspection by the fire code official.
<b>105.6.1</b>	<b>Aerosol products</b>	An operational permit is required to manufacture, store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 pounds (227 kg) net weight.
<b>105.6.2</b>	<b>Amusement buildings</b>	An operational permit is required to operate a special amusement building.
<b>105.6.3</b>	<b>Aviation facilities</b>	An operational permit is required to use a Group H or Group S occupancy for aircraft servicing or repair and aircraft fuel-servicing vehicles. Additional permits required by other sections of this code include, but are not limited to, hot work, hazardous materials and flammable or combustible finishes.
<b>105.6.4</b>	<b>Carbon dioxide systems</b>	An operational permit is required for carbon dioxide systems having more than 100 pounds of carbon dioxide.
<b>105.6.5</b>	<b>Carnivals and fairs</b>	An operational permit is required to conduct a carnival or fair.
<b>105.6.6</b>	<b>Cellulose nitrate film</b>	An operational permit is required to store, handle or use cellulose nitrate film in a Group A occupancy.
<b>105.6.7</b>	<b>Combustible dust-producing operations</b>	An operational permit is required to operate a grain elevator, flour starch mill, feed mill, or a plant pulverizing aluminum, coal, cocoa, magnesium, spices or sugar, or other operations producing combustible dusts as defined in Chapter 2.
<b>105.6.8</b>	<b>Combustible fibers</b>	An operational permit is required for the storage and handling of combustible fibers in quantities greater than 100 cubic feet (2.8 m <sup>3</sup> ). <b>Exception:</b> A permit is not required for agricultural storage.

<b>105.6.9</b>	<b>Compressed gases</b>	<p>An operational permit is required for the storage, use or handling at normal temperature and pressure (NTP) of compressed gases in excess of the amounts listed in Table 105.6.9.</p> <p><b>Exception:</b> Vehicles equipped for and using compressed gas as a fuel for propelling the vehicle.</p> <p style="text-align: center;"><b>Table 105.6.9</b></p> <table border="1" data-bbox="586 327 1515 688"> <thead> <tr> <th>Type of Gas</th> <th>Amount (Cu. Ft. at NTP)</th> </tr> </thead> <tbody> <tr> <td>Corrosive</td> <td>200</td> </tr> <tr> <td>Flammable</td> <td>200</td> </tr> <tr> <td>Highly Toxic</td> <td>Any Amount</td> </tr> <tr> <td>Inert and simple asphyxiant</td> <td>6,000</td> </tr> <tr> <td>Oxidizing (including oxygen)</td> <td>504</td> </tr> <tr> <td>Pyrophoric</td> <td>Any Amount</td> </tr> <tr> <td>Toxic</td> <td>Any Amount</td> </tr> </tbody> </table>	Type of Gas	Amount (Cu. Ft. at NTP)	Corrosive	200	Flammable	200	Highly Toxic	Any Amount	Inert and simple asphyxiant	6,000	Oxidizing (including oxygen)	504	Pyrophoric	Any Amount	Toxic	Any Amount
Type of Gas	Amount (Cu. Ft. at NTP)																	
Corrosive	200																	
Flammable	200																	
Highly Toxic	Any Amount																	
Inert and simple asphyxiant	6,000																	
Oxidizing (including oxygen)	504																	
Pyrophoric	Any Amount																	
Toxic	Any Amount																	
<b>105.6.10</b>	<b>Covered mall buildings</b>	<p>An operational permit is required for:</p> <ol style="list-style-type: none"> <li>1. The placement of retail fixtures and displays, concession equipment, displays of highly combustible goods and similar items in the mall.</li> <li>2. The display of liquid- or gas-fired equipment in the mall.</li> <li>3. The use of open-flame or flame-producing equipment in the mall.</li> </ol>																
<b>105.6.11</b>	<b>Cryogenic fluids</b>	<p>An operational permit is required to produce, store, transport on site, use, handle or dispense cryogenic fluids in excess of the amounts listed in Table 105.6.11.</p> <p style="text-align: center;"><b>Table 105.6.11</b></p> <table border="1" data-bbox="586 1234 1515 1514"> <thead> <tr> <th>Type of Cryogenic Fluid</th> <th>Inside Building (gallons)</th> <th>Outside Building (gallons)</th> </tr> </thead> <tbody> <tr> <td>Flammable</td> <td>More than 1</td> <td>60</td> </tr> <tr> <td>Inert</td> <td>60</td> <td>500</td> </tr> <tr> <td>Oxidizing (includes oxygen)</td> <td>10</td> <td>50</td> </tr> <tr> <td>Physical or health hazard not indicated above</td> <td>Any Amount</td> <td>Any Amount</td> </tr> </tbody> </table>	Type of Cryogenic Fluid	Inside Building (gallons)	Outside Building (gallons)	Flammable	More than 1	60	Inert	60	500	Oxidizing (includes oxygen)	10	50	Physical or health hazard not indicated above	Any Amount	Any Amount	
Type of Cryogenic Fluid	Inside Building (gallons)	Outside Building (gallons)																
Flammable	More than 1	60																
Inert	60	500																
Oxidizing (includes oxygen)	10	50																
Physical or health hazard not indicated above	Any Amount	Any Amount																
<b>105.6.12</b>	<b>Cutting and welding</b>	<p>An operational permit is required to conduct cutting or welding operations within the jurisdiction.</p>																
<b>105.6.13</b>	<b>Dry cleaning plants</b>	<p>An operational permit is required to engage in the business of dry cleaning or to change to a more hazardous cleaning solvent used in existing dry cleaning equipment.</p>																
<b>105.6.14</b>	<b>Exhibits and trade shows</b>	<p>An operational permit is required to operate exhibits and trade shows.</p>																
<b>105.6.15</b>	<b>Explosives</b>	<p>An operational permit is required for the manufacture, storage, handling, sale or use of any quantity of explosives, explosive materials, fireworks or pyrotechnic special effects within the scope of Chapter 56.</p>																

<p><b>105.6.16</b></p>	<p><b>Fire hydrants and valves</b></p>	<p>An operational permit is required to use or operate fire hydrants or valves intended for fire suppression purposes which are installed on water systems and accessible to a fire apparatus access road that is open to or generally used by the public.</p> <p><b>Exception:</b> A permit is not required for authorized employees of the water company that supplies the system or the fire department to use or operate fire hydrants or valves.</p>
<p><b>105.6.17</b></p>	<p><b>Flammable and combustible liquids</b></p>	<p>An operational permit is required:</p> <ol style="list-style-type: none"> <li>1. To use or operate a pipeline for the transportation within facilities of flammable or combustible liquids. This requirement shall not apply to the off-site transportation in pipelines regulated by the Department of Transportation (DOTn) nor does it apply to piping systems.</li> <li>2. To store, handle or use Class I liquids in excess of 5 gallons (19 L) in a building or in excess of 10 gallons (37.9 L) outside of a building, except that a permit is not required for the following: <ol style="list-style-type: none"> <li>2.1. The storage or use of Class I liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant or mobile heating plant, or storage of approved portable motor boat fuel containers of six (6) gallons or less individual capacity and (12) twelve gallons aggregate capacity, unless such storage, in the opinion of the code official, would cause an unsafe condition.</li> <li>2.2. The storage or use of paints, oils, varnishes or similar flammable mixtures when such liquids are stored for maintenance, painting or similar purposes for a period of not more than 30 days.</li> </ol> </li> <li>3. To store, handle or use Class II or Class IIIA liquids in excess of 25 gallons (95 L) in a building or in excess of 60 gallons (227 L) outside a building, except for fuel oil used in connection with oil-burning equipment.</li> <li>4. To store, handle or use Class IIIB liquids in tanks or portable tanks for fueling motor vehicles at motor fuel-dispensing facilities or where connected to fuel-burning equipment.</li> </ol> <p>Exception: Fuel oil and used motor oil used for space heating or water heating.</p> <ol style="list-style-type: none"> <li>5. To remove Class I or II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved , stationary on-site pumps normally used for dispensing purposes.</li> <li>6. To operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries and similar facilities</li> </ol>

		<p>where flammable and combustible liquids are produced, processed, transported, stored, dispensed or used.</p> <p>7. To place temporarily out of service (for more than 90 days) an underground, protected above-ground or above-ground flammable or combustible liquid tank.</p> <p>8. To change the type of contents stored in a flammable or combustible liquid tank to a material that poses a greater hazard than that for which the tank was designed and constructed.</p> <p>9. To manufacture, process, blend or refine flammable or combustible liquids.</p> <p>10. To engage in the dispensing of liquid fuels into the fuel tanks of motor vehicles at commercial, industrial, governmental or manufacturing establishments.</p> <p>11. To utilize a site for the dispensing of liquid fuels from tank vehicles into the fuel tanks of motor vehicles, marine craft and other special equipment at commercial, industrial, governmental or manufacturing establishments.</p> <p>12. To engage in the business of removing, abandoning or otherwise disposing of residential heating oil tanks.</p>
<b>105.6.18</b>	<b>Floor finishing</b>	An operational permit is required for floor finishing or surfacing operations exceeding 350 square feet (33 m <sup>2</sup> ) using Class I or Class II liquids.
<b>105.6.19</b>	<b>Fruit and crop ripening</b>	An operational permit is required to operate a fruit- or crop-ripening facility or conduct a fruit-ripening process using ethylene gas.
<b>105.6.20</b>	<b>Fumigation and thermal insecticidal fogging</b>	An operational permit is required to operate a business of fumigation or thermal insecticidal fogging and to maintain a room, vault or chamber in which a toxic or flammable fumigant is used.

**105.6.20**

**Hazardous materials**

An operational permit is required to store, transport on site, dispense, use or handle hazardous materials in excess of the amounts listed in Table 105.6.21.

**Table 105.6.21**

Type of Material	Amount
Combustible liquids	See Section 105.6.17
Corrosive materials	
Gases	See Section 105.6.9
Liquids	55 gallons
Solids	1000 pounds
Explosive materials	See Section 105.6.15
Flammable materials	
Gases	See Section 105.6.9
Liquids	See Section 105.6.17
Solids	100 pounds
Highly toxic materials	
Gases	See Section 105.6.9
Liquids	Any Amount
Solids	Any Amount
Oxidizing materials	
Gases	See Section 105.6.9
Liquids	
Class 4	Any Amount
Class 3	1 gallon
Class 2	10 gallons
Class 1	55 gallons
Solids	
Class 4	Any Amount
Class 3	10 pounds
Class 2	100 pounds
Class 1	500 pounds
Organic peroxides	
Liquids	
Class I	Any Amount
Class II	Any Amount
Class III	1 gallon
Class IV	2 gallons
Class V	No permit required
Solids	
Class I	Any Amount
Class II	Any Amount
Class III	10 pounds
Class IV	20 pounds
Class V	No permit required

		<p>Pyrophoric materials</p> <p>Gases Any Amount</p> <p>Liquids Any Amount</p> <p>Solids Any Amount</p>
		<p>Toxic materials</p> <p>Gases See Section 105.6.9</p> <p>Liquids 10 gallons</p> <p>Solids 100 pounds</p>
		<p>Unstable (reactive) materials</p> <p>Liquids</p> <p>Class 4 Any Amount</p> <p>Class 3 Any Amount</p> <p>Class 2 5 gallons</p> <p>Class 1 10 gallons</p> <p>Solids</p> <p>Class 4 Any Amount</p> <p>Class 3 Any Amount</p> <p>Class 2 50 pounds</p> <p>Class 1 100 pounds</p>
		<p>Water-reactive materials</p> <p>Liquids</p> <p>Class 3 Any Amount</p> <p>Class 2 5 gallons</p> <p>Class 1 55 gallons</p> <p>Solids</p> <p>Class 3 Any Amount</p> <p>Class 2 50 pounds</p> <p>Class 1 500 pounds</p>
<b>105.6.22</b>	<b>HPM facilities</b>	An operational permit is required to store, handle or use hazardous production materials.
<b>105.6.23</b>	<b>High-piled storage</b>	An operational permit is required to use a building or portion thereof as a high-piled storage area exceeding 500 square feet (46 m <sup>2</sup> ).
<b>105.6.24</b>	<b>Hot work operations</b>	<p>An operational permit is required for hot work including, but not limited to:</p> <ol style="list-style-type: none"> <li>1. Public exhibitions and demonstrations where hot work is conducted.</li> <li>2. Use of portable hot work equipment inside a structure.</li> </ol> <p><b>Exception:</b> Work that is conducted under a construction permit.</p> <ol style="list-style-type: none"> <li>3. Fixed-site hot work equipment, such as welding booths.</li> <li>4. Hot work conducted within a wildfire risk area.</li> </ol>

		<p>5. Application of roof coverings with the use of an open-flame device.</p> <p>6. When <i>approved</i>, the <i>fire code official</i> shall issue a permit to carry out a hot work program. This program allows approved personnel to regulate their facility's hot work operations. The approved personnel shall be trained in the fire safety aspects denoted in this chapter and shall be responsible for issuing permits requiring compliance with the requirements found in Chapter 35. These permits shall be issued only to their employees or hot work operations under their supervision.</p>
<b>105.6.25</b>	<b>Industrial ovens</b>	An operational permit is required for operation of industrial ovens.
<b>105.6.26</b>	<b>Lumber yards and woodworking plants</b>	An operational permit is required for the storage or processing of lumber exceeding 100,000 board feet (8,333 ft <sup>3</sup> ) (236 m <sup>3</sup> ).
<b>105.6.27</b>	<b>Liquid- or gas-fueled vehicles or equipment in assembly buildings</b>	An operational permit is required to display, operate or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings.
<b>105.6.28</b>	<b>LP-gas</b>	<p>An operational permit is required for:</p> <p>1. Storage and use of LP-gas.</p> <p><b>Exception:</b> A permit is not required for individual containers with a 500-gallon (1893 L) water capacity or less serving occupancies in Group R-3.</p> <p>2. Operation of cargo tankers that transport LP-gas.</p>
<b>105.6.29</b>	<b>Magnesium</b>	An operational permit is required to melt, cast, heat treat or grind more than 10 pounds (4.54 kg) of magnesium.
<b>105.6.30</b>	<b>Miscellaneous combustible storage</b>	An operational permit is required to store in any building or upon any premises in excess of 2,500 cubic feet (71 m <sup>3</sup> ) gross volume of combustible empty packing cases, boxes, barrels or similar containers, rubber tires, rubber, cork or similar combustible material.
<b>105.6.31</b>	<b>Motor fuel-dispensing facilities</b>	An operational permit is required for the operation of automotive, marine and fleet motor fuel-dispensing facilities.
<b>105.6.32</b>	<b>Open burning</b>	<p>An operational permit is required for the kindling or maintaining of an open fire or a fire on any public street, alley, road, or other public or private ground. Instructions and stipulations of the permit shall be adhered to.</p> <p><b>Exception:</b> Recreational fires.</p>

		Open burning shall not be conducted at any time in compliance with a permanent ban on open burning established by the Puget Sound Air Pollution Control Agency in September of 1992. For air quality and burn ban status information and regulations contact the Puget Sound Clean Air Agency at <a href="http://www.pscleanair.org">www.pscleanair.org</a> or (206) 689-4088.
<b>105.6.33</b>	<b>Open flames and torches</b>	An operational permit is required to remove paint with a torch; or to use a torch or open-flame device in a wildfire risk area.
<b>105.6.34</b>	<b>Open flames and candles</b>	An operational permit is required to use open flames or candles in connection with assembly areas, dining areas of restaurants or drinking establishments.
<b>105.6.35</b>	<b>Organic coatings</b>	An operational permit is required for any organic-coating manufacturing operation producing more than 1 gallon (4 L) of an organic coating in one day.
<b>105.6.36</b>	<b>Places of assembly</b>	An operational permit is required to operate a place of assembly.
<b>105.6.37</b>	<b>Private fire hydrants</b>	An operational permit is required for the removal from service, use or operation of private fire hydrants.  <b>Exception:</b> A permit is not required for private industry with trained maintenance personnel, private fire brigade or fire departments to maintain test and use private hydrants.
<b>105.6.38</b>	<b>Pyrotechnic special effects material</b>	An operational permit is required for use and handling of pyrotechnic special effects material.
<b>105.6.39</b>	<b>Pyroxylin plastics</b>	An operational permit is required for storage or handling of more than 25 pounds (11 kg) of cellulose nitrate (pyroxylin) plastics and for the assembly or manufacture of articles involving pyroxylin plastics.
<b>105.6.40</b>	<b>Refrigeration equipment</b>	An operational permit is required to operate a mechanical refrigeration unit or system.
<b>105.6.41</b>	<b>Repair garages and motor fuel-dispensing facilities</b>	An operational permit is required for operation of repair garages.
<b>105.6.42</b>	<b>Rooftop heliports</b>	An operational permit is required for the operation of a rooftop heliport.
<b>105.6.43</b>	<b>Spraying or dipping</b>	An operational permit is required to conduct a spraying or dipping operation utilizing flammable or combustible liquids or the application of combustible powders regulated by Chapter 24.
<b>105.6.44</b>	<b>Storage of scrap tires and tire byproducts</b>	An operational permit is required to establish, conduct or maintain storage of scrap tires and tire byproducts that exceeds 2,500 cubic feet (71 m <sup>3</sup> ) of total volume of scrap tires and for indoor storage of tires and tire byproducts.



<b>105.6.45</b>	<b>Temporary membrane structures and tents</b>	<p>An operational permit is required to operate an air-supported temporary membrane structure or a tent having an area in excess of 400 square feet (37 m<sup>2</sup>).</p> <p><b>Exceptions:</b></p> <ol style="list-style-type: none"> <li>1. Tents used exclusively for recreational camping purposes.</li> <li>2. Tents open on all sides, which comply with all of the following: <ol style="list-style-type: none"> <li>2.1. Individual tents having a maximum size of 700 square feet (65 m<sup>2</sup>).</li> <li>2.2. The aggregate area of multiple tents placed side by side without a fire break clearance of not less than 12 feet (3658 mm) shall not exceed 700 square feet (65 m<sup>2</sup>) total.</li> <li>2.3. A minimum clearance of 12 feet (3658 mm) to structures and other tents shall be provided.</li> </ol> </li> </ol>
<b>105.6.46</b>	<b>Tire-rebuilding plants</b>	An operational permit is required for the operation and maintenance of a tire-rebuilding plant.
<b>105.6.47</b>	<b>Waste handling</b>	An operational permit is required for the operation of wrecking yards, junk yards and waste material-handling facilities.
<b>105.6.48</b>	<b>Wood products</b>	An operational permit is required to store chips, hogged material, lumber or plywood in excess of 200 cubic feet (6 m <sup>3</sup> ).
<b>105.6.49</b>	<b>Marijuana extraction systems</b>	An operational permit is required to use a marijuana/cannabis extraction system regulated under WAC 314-55-104.
<b>105.6.50</b>	<b>Emergency responder radio coverage system</b>	An operational permit is required to operate an Emergency Responder Radio Coverage System as prescribed in Bellevue City Code 23.11.510.
<b>105.6.51</b>	<b>Positive alarm sequence</b>	An operational permit is required to operate a PAS (Positive Alarm Sequence) Account as prescribed in NFPA (National Fire Protection Association) 72.23.11.